

**Data Sheet | Item Number: 2002-423**

Continuous jumper; from 1 to 3; insulated; light gray

<https://www.wago.com/2002-423>



Color:  light gray

### Electrical data

|               |      |
|---------------|------|
| Rated current | 25 A |
|---------------|------|

## Physical data

|        |                        |
|--------|------------------------|
| Width  | 10.9 mm / 0.429 inches |
| Height | 4.1 mm / 0.161 inches  |
| Depth  | 18.5 mm / 0.728 inches |

## Material data

|           |            |
|-----------|------------|
| Color     | light gray |
| Fire load | 0.004 MJ   |
| Weight    | 0.8 g      |

## Commercial data

|                       |               |
|-----------------------|---------------|
| PU (SPU)              | 25 pcs        |
| Packaging type        | Bag           |
| Country of origin     | DE            |
| GTIN                  | 4055143690874 |
| Customs tariff number | 85366990990   |

| Product Classification |                      |
|------------------------|----------------------|
| UNSPSC                 | 39121421             |
| eCl@ss 10.0            | 27-14-11-40          |
| eCl@ss 9.0             | 27-14-11-40          |
| ETIM 9.0               | EC000489             |
| ETIM 10.0              | EC000489             |
| ECCN                   | NO US CLASSIFICATION |

| Environmental Product Compliance |                         |
|----------------------------------|-------------------------|
| RoHS Compliance Status           | Compliant, No Exemption |

| Environmental requirements                                                                          |                                                     |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------|
| Environmental Testing                                                                               |                                                     |
| Test specification:<br>Railway applications –<br>Rolling stock –<br>Electronic equipment            | DIN EN 50155 (VDE 0115-200):2022-06                 |
| Test procedure:<br>Railway applications –<br>Rolling stock equipment –<br>Vibration and shock tests | DIN EN 61373 (VDE 0115-0106):2011-04                |
| Spectrum/Mounting location                                                                          | Service life test, Category 1, Class A/B            |
| Functional test with noise-like oscillations                                                        | Test passed according to Section 8 of the standard  |
| Frequency                                                                                           | f <sub>1</sub> = 5 Hz to f <sub>2</sub> = 150 Hz    |
| Acceleration                                                                                        | 0.101g (highest test level used for all axes)       |
| Test duration per axis                                                                              | 10 min.                                             |
| Test directions                                                                                     | X, Y and Z axes                                     |
| Monitoring of contact faults and interruptions                                                      | Passed                                              |
| Voltage drop measurement before and after each axis                                                 | Passed                                              |
| Simulated service life test through increased levels of noise-like oscillations                     | Test passed according to Section 9 of the standard  |
| Frequency                                                                                           | f <sub>1</sub> = 5 Hz to f <sub>2</sub> = 150 Hz    |
| Acceleration                                                                                        | 0.572g (highest test level used for all axes)       |
| Test duration per axis                                                                              | 5 h                                                 |
| Test directions                                                                                     | X, Y and Z axes                                     |
| Extended testing: Monitoring of contact faults and interruptions                                    | Passed                                              |
| Extended testing: Voltage drop measurement before and after each axis                               | Passed                                              |
| Shock test                                                                                          | Test passed according to Section 10 of the standard |
| Shock pulse form                                                                                    | Half sine                                           |
| Acceleration                                                                                        | 5g (highest test level used for all axes)           |
| Shock duration                                                                                      | 30 ms                                               |
| Number of shocks (per axis)                                                                         | 3 pos. und 3 neg.                                   |
| Test directions                                                                                     | X, Y and Z axes                                     |
| Extended testing: Monitoring of contact faults and interruptions                                    | Passed                                              |
| Extended testing: Voltage drop measurement before and after each axis                               | Passed                                              |
| Vibration and shock stress for rolling stock equipment                                              | Passed                                              |



Approvals / Certificates

Declarations of conformity and manufacturer's declarations



| Approval                      | Standard | Certificate Name |
|-------------------------------|----------|------------------|
| Railway<br>WAGO GmbH & Co. KG | -        | Railway Ready    |

Downloads

Environmental Product Compliance

| Compliance Search                            |
|----------------------------------------------|
| Environmental Product<br>Compliance 2002-423 |



Documentation

| Bid Text |            |                 |                                                                                                   |
|----------|------------|-----------------|---------------------------------------------------------------------------------------------------|
| 2002-423 | 19.02.2019 | xml<br>2.56 KB  | <a href="#"></a> |
| 2002-423 | 27.04.2017 | doc<br>23.50 KB | <a href="#"></a> |

CAD/CAE-Data

| CAD data              |
|-----------------------|
| 2D/3D Models 2002-423 |




| CAE data                      |
|-------------------------------|
| EPLAN Data Portal<br>2002-423 |
| WSCAD Universe<br>2002-423    |
| ZUKEN Portal 2002-423         |



Installation Notes

Commoning



The 1-to-3 adjacent jumper for continuous commoning enables every other terminal block to be commoned. For example, positive and negative potentials can be accommodated alongside each other.

## Commoning



By combining a 1-to-2 continuous jumper with a 1-to-3 adjacent jumper, various commoning applications can be performed in just one jumper slot.